

Engineering Design Standard Section 3-1

Date: 11-30-15

## ADDENDUM TO BUCKEYE WATER DESIGN STANDARDS

Request No. <u>5</u>	APPROVED: <u>Y</u> / N	ADDENDUM NUMBER <u>W-3</u>
----------------------	------------------------	----------------------------

This addendum is based on the City of Buckeye Engineering Design Standards adopted by City Council in Resolution No. 133-12.

The requirements of the buckeye Design Standards section may be modified at any time by the City Engineer pursuant to Chapter 23, Article 23-2 and adopted by City Council.

The standards, design criteria, and policy set forth in this section were developed and recommended by the City Engineer.

The following changes will be in full effect after the signature date, and supersedes the originally approved standards and details as formerly written.

**Revised Standard Number:** 3-1.207 (P)

**Original text/Detail:**

"Valve boxes shall be installed per MAG Standard Detail 391-1, Type "C" and shall be heavy duty with a minimum lid height of 6 inches."

**Revised Text/Detail:**

Valve boxes shall be installed per MAG Standard Detail 391-2."

This addendum shall cover all instances of the substitution of MAG Standard Detail 391-1, Type "C" with MAG Standard Detail 391-2.

**Authored By:** Craig Sharp

**NOTES:** This modification is requested by Arnold Coronado Water Distribution Supervisor.

**Approved By:** Jean Mackin 1-14-16  
City Engineer Date