
Racking Submittal Checklist

- Completed Permit Application
- Site Plan – 2 copies
- Building Information – 2 copies of plan
 1. Occupancy Group
 2. Construction Type
 3. Total Square footage of building
- Floor Plan
 1. Location of proposed racking
 2. Provide aisle widths
 3. List square footage of floor storage
 4. Linear feet of racking called out
 5. Provide the following heights:
 - What is the commodity height above rack?
 - Height of Solid Pile Area
 - Distance from top of storage to bottom of roof joists.
 6. Description of stacked commodities
 - **Commodities:** Please reference most current adopted Fire Code. Class I Class II Class III Class IV HIGH
 - **If plastics:** Please reference most current adopted Fire Code. Group A Group B Group C _____ % of PLASTIC
 7. Type of Racking: Single Row Double Row Multi-Row Automatic Storage
 8. Include a stamp or statement from the registered design professional in responsible charge indicating that the deferred submittal documents have been reviewed and found to be in general conformance to the design of the building.
 9. Fire sprinklers/alarms systems must also be approved by the State Fire Marshall or City of Buckeye Fire Department.
- HAZARDOUS MATERIALS :**
Are there hazardous materials in the building?

If yes, please provide the following information with submittal:
 1. Material Safety Data Sheets (M.S.D.S.)
 2. How is the material stored? (Racks, Cabinets, Floor, etc.)
 3. Containment? Yes No