


CONSTRUCTION NOTES

1. 4 INCH CLASS 350 D.I.P.
2. THRUST BLOCK PER MAG STD DETAIL 380.
3. 4 INCH WRAPPED STEEL PIPE PER FIRE CODE, MAG STD DETAIL 610, & A.W.W.A. "C" 150. EXPOSED MATERIAL TO BE PROTECTED WITH AN APPROVED PAINT/MATERIAL.
4. APPROVED CHECK VALVE.
5. STANDARD BRASS FDC FEMALE THREADED CONNECTION (2) 2½" NST CLAPPERED WITH NO VALVES.
6. BRASS MALE THREADED CONNECTION WYE (2) 2½" NST GATED VALVES WITH CAPS.
7. 4 INCH FLANGED D.I.P. TEE
8. 4 INCH FLANGED D.I.P. 90° EL.
9. STANDPIPE SIGNAGE PER TOB STD DETAIL FD-104 SIGNAGE "A".



TOP VIEW

 TOWN OF BUCKEYE, ARIZONA STANDARD CONSTRUCTION DETAILS	MULTIPLE FEED HORIZONTAL STANDPIPES	DATE	REVISED	DETAIL #
		05/2007	N/A	FD-103