

**SOLICITATION AMENDMENT
RFP No. 418004
CITY OF BUCKEYE
CONSTRUCTION & CONTRACTING DIVISION
623.349.6171**

AMENDMENT #1

NOTE: Attach to Original RFP. However, if Proposal has already been returned, complete this amendment and return for attachment to your Proposal by 4:00pm, June 14, 2018.

City of Buckeye
530 East Monroe Avenue
Buckeye, Arizona 85326
Attn: Tyra Bell, Purchasing Agent

SOLICITATION: RFP No. 418004: Water/Wastewater Treatment Chemicals

NOTICE TO VENDORS:

This Amendment forms a part of the Contract and clarifies, corrects, or modifies the original Request for Proposals documents prepared by the City of Buckeye.

Bid Due Date and Time: **June 14, 2018 at 4:00 PM**

Last Day for Questions: **June 7, 2018 at 5:00 PM**

THE FOLLOWING QUESTIONS WERE ASKED BY VENDORS:

Q1: Per the bid we are to provide pricing and our minimum quantity for both full truck loads and less than truck loads – however is there an estimated desired minimum quantity for deliveries?

A1: Water:

Production expects the average load of chlorine to be 150-650 gallons depending on the site. Ferric Chloride is approximately 300 gallons at Sonoran Vista. Ferric Sulfate is a full truck load split between North Airport and Sundance WTF. Sulfuric Acid 1500 gallons a load. The city receives approximately 350-1000 lbs. of carbon dioxide at Sonoran Ridge and Buckeye Airport #2.

Wastewater:

The city has small tanks at Tartesso and Festival. Tartesso will take 1000 gallons of liquid bleach and 600 of Caustic. Festival will take 300 gallons of bleach and 300 gallons of Caustic.

Q2: Is there more details specifications for these chemicals (i.e., NSF required, no organic or inorganic materials, specific range, pH, etc)?

A2: Water:

NSF is required for drinking water.

Wastewater:

Bleach is 12.5% and 33% Caustic.

Polymer, Liquid – Praestol K 274 FLX or NSF Approved Equal

Q3: Are there any other delivery requirements (i.e. specific length of hoses, tank trucks, pallet jacks, etc.)?

A3: Water:

Vendors have been providing a pallet jack thus far and the pool truck is easier to deliver at the smaller sites. The standard hose that has been on the truck has been adequate. Approximately 50-75 feet.

Wastewater:

All deliveries have chemical connection close by so no extra equipment is needed.

Q4: Polymer is to be shipped in Totes – what size totes (i.e. 275 lbs.)?

A4: Water:

N/A

Wastewater:

All totes are 300 gallons and all drums are 50 gallons.

Q5: Are the volumes shown for the polymers for each plant in gallons or pounds? For example for the central plant it states the container size is Totes then 20,000, is that pounds per year?

A5: Water:

N/A

Wastewater:

The volume is in net pounds. Each tote contains roughly 2,290 lbs. or 300 gallons. Each drum is roughly 450 lbs. or 50 gallons.

Q6: Could you possibly provide the previous bid tabulations?

A6: Water and Wastewater:

The city does not have a previous bid tabulation. We have been using cooperative contracts through the State of Arizona and the City of Chandler

The balance of the specifications and instructions remain the same. Vendors must acknowledge receipt and acceptance of this amendment by returning the entire amendment with the Proposal.

PLEASE ACKNOWLEDGE YOUR FIRM'S RECEIPT OF THIS AMENDMENT BY SIGNING THE ATTACHED SOLICITATION AMENDMENT ACKNOWLEDGEMENT.

SOLICITATION AMENDMENT ACKNOWLEDGEMENT

RFP No. 418004

AMENDMENT NUMBER 1

AMENDMENT ISSUE DATE: May 29, 2018

Vendor certifies that Vendor has read, understands, and will fully and faithfully comply with this Request for Proposals, its attachments and any referenced documents. Vendor also certifies that this offer was independently developed without consultation with any of the other Vendors or potential Vendors.

Name of Company: _____

Authorized Signature: _____

Print Name and Title: _____

Date: _____

Address: _____

City, State, Zip Code: _____

Telephone Number: _____

Email Address: _____